

3,750 KVA TRANSFORMER BIDS

	Tech. Electric		NEXT Electric	
	VanTran	Eaton / Cooper	VanTran	Eaton / Cooper
Bid Price	\$243,900.00	\$206,100.00	\$565,858.00	\$469,428.00
Actual Price	\$487,800.00 [1]	\$412,200.00 [1]	\$565,858.00 [1]	\$469,428.00 [1]
BABA	YES	YES	YES	YES
Lead Time	30 weeks after approved submittal	114 weeks after approved submittal	30 weeks after approved submittal	114 weeks after approved submittal
Core Design	5-Legged	5-Legged	5-Legged	5-Legged
Dimensions	None Given	None Given	80" W x 91" D x 82" H	None Given
NOTES	[1] Bid price was a unit price for one Transformer. Actual price reflects QTY 2.		[1] Submitted Bid price assumed to reflect QTY 2.	
	Donohue recommendation based on lead time.		Lead time does not meet delivery time spec.	

24.9KV SWITCHGEAR BIDS

	T&D Products	Tech Electric	NEXT Electric
	Avail - Power Grid Solutions	S&C	S&C
Bid Price	\$219,920.00	\$296,930.00	\$444,643.00
BABA	YES	NO	NO
Lead Time	50 weeks ARO	75 weeks ARO	110 weeks ARO
Dimensions	144" W x 84" D x 129" H	180" W x 59" D x 129" H	180" W x 59" D x 129" H
NOTES	Requires 240/120VAC & 125VDC Control Power (Batteries). Installed cost requires additional costs for program of relays, aux power, and batteries/charger. Requires third-party protective relaying (SEL).		
	Failed to provide installations with switchgear similar to what is required for this project and, as a result, does not meet spec: Section 26 13 00, Paragraph 1.03A.		Lead time does not meet delivery time spec.

_____ Fails to meet spec.

_____ Recommended.